

甲府市M様邸灯油使用料

給湯

暖房

測定日	給湯 (ℓ)	日数	消費量	平均消費量/日
2018/5/9	9.5			
		31.0	2.8	0.09
2018/6/9	12.3			
		30.0	2.0	0.06
2018/7/9	14.3			
		31.0	1.6	0.05
2018/8/9	15.9			
		31.0	1.2	0.04
2018/9/9	17.1			
		30.0	1.2	0.04
2018/10/9	18.3			
		31.0	2.0	0.06
2018/11/9	20.3			
		30.0	2.4	0.08
2018/12/9	22.7			
		31.0	7.1	0.23
2019/1/9	29.8			
		31.0	3.7	0.12
2019/2/9	33.5			
		28.0	5.3	0.17
2019/3/9	38.8			
		31.0	1.6	0.05
2019/4/9	40.4			
		30.0	2.7	0.09
2019/5/9	43.0			
		31.0	0.2	0.01
2019/6/9	43.2			
		30.0	2.8	0.09
2019/7/9	46.0			

暖房 (ℓ)	日数	消費量	平均消費量/日
19.2			
	31.0	0.00	0.00
19.2			
	30.0	0.00	0.00
19.2			
	31.0	0.00	0.00
19.2			
	31.0	0.00	0.00
19.2			
	30.0	0.00	0.00
19.2			
	31.0	10.78	0.35
30.0			
	30.0	49.52	1.65
79.5			
	31.0	101.30	3.27
180.8			
	31.0	110.00	3.55
290.8			
	28.0	84.50	3.02
375.3			
	31.0	56.20	1.81
431.5			
	30.0	11.78	0.39
443.3			
	31.0	0.00	0.00
443.3			
	30.0	0.32	0.01
443.6			

139.78㎡ (42.36坪)

33.5 ℓ/年

424.1 ℓ/年

QPEXによる予測計算値 247ℓ/年~20℃設定

★22℃設定で計算すると、436ℓとなる

0.24 ℓ/㎡・年

3.03 ℓ/㎡・年

